

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1575:106 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: IntelliSense, 625 Coolidge Drive, Folsom, CA 95630
Contact: *Steve Aguilar (916) 353-5300 Fax (916) 985-6851

DESIGN: Model "Brinks" BHS 3000A combination residential fire and burglary alarm control unit.
Refer to listee's data sheet for detailed product description and operational considerations. System components:

"Brinks" BHS-3000A	Control unit
S3111B	LED Keypad
S3101B	ICON Keypad
BHS-3111	Brinks LED Keypad
BHS-3101	Brinks ICON Keypad
S3201	8 -Zone Expansion Module

RATING: 120/16.5 VAC-Primary, 12 VDC-Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as residential fire alarm control unit when used in conjunction with separately listed compatible initiating and indicating signaling devices.

Unit can generate a distinctive three-pulse temporal Pattern Fire Alarm Evacuation Signal as required per NFPA 72, 1996 edition. Refer to listee's Installation Manual for details.

NOTE:

1. Burglary and other non-fire functions not examined.
2. Fire Alarm Verification Feature (delay of fire alarm signal) shall NOT be used in California

*Rev. 06-06-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager